

Scott County Administration-Purchasing Division

REQUEST FOR QUOTATION

Scott County Requisition No. 19362

Bidders need to complete and submit this form.

Submission Date: 2/23/2018	No Later Than:10:00 a.m.
-----------------------------------	---------------------------------

Qty	Description
	UPS Battery Replacement for Juvenile Detention Facility
	Scope of work is attached, including make and model information
	Please submit any inquiries or questions to www.publicpurchase.com
	Responses to this request are to be returned to
	www.publicpurchase.com
	Delivery Included
	price quotation good for 60 days
	From time to time it may be necessary to change or modify a request for purchase. If you have received this request from any other source other than direct fax or email from Scott County, it is your responsibility to check for updates and/or changes to the request. If you would like to receive automatic updates please register your company in our vendor data base by using our website, www.scottcountyiowa.com

Scott County reserves the right to accept the bid from the lowest responsible bidder.

Quote submitted by:

Released by:
(Scott County Use Only)

Name

Date: 2/13/2018

Time: 1:00 p.m.

Title

Company

PLEASE NOTE:

Bidders must provide an estimated delivery date in their bid response!

Date

Company Contact Information:	Phone:
	E-Mail:

“By virtue of statutory authority, a preference will be given to products and provisions grown and coal produced within the State of Iowa.”

UPS Battery Replacement for Scott County Facility & Support Services

Scott County Facility and Support Services wishes to receive cost estimates for the removal and replacement of (24) batteries for a UPS system by a professionally trained UPS technician at 500 West 4th Street in Davenport, IA 52801.

Location is the Scott County Juvenile Detention Center.

MAKE: LEIBERT UPS SYSTEM

MODEL: NXB20

SERIAL NUMBER: 4750700001

KVA: 20

Cost Estimates Shall Include the Following Information:

- 1. Removal, Replacement, Delivery, and Disposal of spent batteries.**
- 2. Standard Warranty and Product Information for Replacement Batteries**
- 3. Standard Labor Cost for Removal and Replacement between Monday – Friday 8 am – 4:30 PM.**
- 4. Lead Time for Batteries**
- 5. All Freight Cost for dock to dock delivery**
- 6. Provide scope of provided services during UPS battery replacement. Scope of services shall include but should not be limited to the list below.**
 - a. Voltage Adjustments to UPS specifications**
 - b. Battery Discharge and Test Integrity**
 - c. Documented Service Report Detailing Battery Replacement and Measurements**
 - d. Any use of specialized metering devices and testing equipment for battery replacement**
 - e. Any necessary cleaning in UPS System or battery posts prior to installation**
 - f. Battery Grease Application (where necessary)**
 - g. Torque specification relative to battery replacement**
 - h. Measurements and recording of battery voltages**
 - i. Battery Jar Inspection**
 - j. Measurement and recording of battery temperature**
 - k. Measurement and recording of Internal Cell resistance**
 - l. Tightness on all inter - unit connectors.**

All bids shall be returned no later than February 23rd. Any bids received after this date will not be accepted.