


Administration

Purchasing Division

600 West Fourth Street
Davenport, Iowa 52801-1030



Ph: (563) 326-8793 Fax: (563) 328-3285
Email: purchasing@scottcountyiowa.com

April 30, 2019

Addendum #1

Request #19448- Periodic Maintenance inspection of SECC Generators

In Scope of Work section

It should read: **One full inspection and three (3) standard inspections.**

Additions to be included:

D. SECC diesel generators fuel analysis performed one time per year on both generators at location listed in attachments A. All documentation to be sent to Maintenance Coordinator Chris Still with FSS

E. SECC Generators to have full load bank testing performed once a year at location listed in attachment A. All documentation to be sent to Chris Still Maintenance Coordinator FSS.