



To: Prospective Bidders

From: Wold Architects and Engineers

Date: August 12, 2026

Comm. No: 213131

Subject: Addendum No. 3 for Bidding Documents for the
YJRC Preaction Fire Protection

*****NOTE CHANGE IN BID DATE*****
BIDS DUE AUGUST 17, 2026 AT 1:00 P.M.

This addendum forms a part of the Contract Documents dated July 10, 2026. Acknowledge receipt of this Addendum on the space provided on the Bid Form. Failure to do so may result in disqualification of Bid.

This Addendum consists of two (2) typed sheets and no attachments.

PRIOR APPROVALS

The following schedule amends designated specification sections to list additional acceptable manufacturers. Use of any product by any of these manufacturers will be permitted only if after review of shop drawings or detailed product data per Section 01 30 00, Architect determines that proposed materials or equipment are equivalent in performance, construction and appearance to product(s) specified.

Where anticipated product substitutions would alter the design or space requirements indicated on the Drawings, pay for cost of design and construction revisions including the cost of associated work by other contractors.

For complete requirements, see Specification Section 01 25 00 – Substitution Procedures.

<u>Section No.</u>	<u>Item</u>	<u>Type</u>	<u>Acceptable Manufacturer</u>
Mechanical Sheets	Nitrogen Product	Generator	Engineered Corrosion Solutions



DRAWINGS

1. DRAWING E3.11b MAIN LEVEL SYSTEMS PLAN – AREA 'B'

- A. Add Keyed Sheet Note #6 to NE corner of Sprinkler Room D105A. Keyed Sheet Note #6 to read "Relocate conduit and boxes behind new valves/switches to an accessible location – verify location in the field with Owner approval."

END OF ADDENDUM #3